

Ohio Residential Plan Submittal Form *Part A*

Address of Project	City/Township	Project Description		
Contractor/DBA	Address	State License No	Phone No	Cell Phone No
Owner	Address	Phone No		Cell Phone No
Electrical Design				
Service Size	Panel Location in dwelling	Size of Service Entrance Cable	Location of Service	
			<input type="checkbox"/> Overhead <input type="checkbox"/> Underground	

Provide additional details or drawings below

NUMBER OF SUB PANELS _____

HVAC Design			
Equipment Type/Size	Location of Equipment	Type of Fuel	Heat Loss/Gain
Sq. Ft. of Conditioned Space	Duct Size (Supply/Return)	Equipment Efficiency Ratings	

Provide additional details or drawings below

As the legal owner/agent of the property above, I am performing the electrical/HVAC work described above.

_____ Date ___/___/___

As the legal owner/agent of the property above, I am performing the electrical/HVAC work described above.

_____ Date ___/___/___

NOTE: Per section 106.1 the Residential Building Official may require additional drawings, technical data or documentation in order to verify compliance.

Building Department Only

Residential Plans Examiner/Building Official	Date of Approval	Application/Permit No

Ohio Residential Plan Submittal Form *Part B*

Referenced Code Text

ELECTRICAL	MECHANICAL																																											
<p>NEC 110.3 All electrical equipment shall be installed and used in accordance with the listing requirements and manufacturer's instructions.</p>	<p>M1401.1 Heating and cooling equipment and appliances shall be installed in accordance with the manufacturer's installation instructions and the requirements of the Residential Code.</p>																																											
Service	Sizing																																											
<p>Size of Service in Amperes:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Copper</th> <th>Aluminum</th> <th>Service Rating</th> <th>NEC 310-15 Conductor Sizes (20/240 VOLT) 3-Wire Single-Phase Dwelling Services/Feeders</th> </tr> </thead> <tbody> <tr> <td><input type="checkbox"/></td> <td>4 AWG</td> <td>2 AWG</td> <td>100 Amps</td> <td></td> </tr> <tr> <td><input type="checkbox"/></td> <td>1 AWG</td> <td>2/0 AWG</td> <td>150 Amps</td> <td></td> </tr> <tr> <td><input type="checkbox"/></td> <td>2/0 AWG</td> <td>4/0 AWG</td> <td>200 Amps</td> <td></td> </tr> </tbody> </table> <p>NEC 250.50 All grounding electrodes that are present at each building or structure served shall be bonded together to form the grounding electrode system. Conductor size per NEC 250.66.</p> <p>NEC 250.52 Permitted Electrodes include:</p> <ol style="list-style-type: none"> 1. Metal underground water pipe in direct contact with earth for 10 feet or more 2. Metal frame of the building 3. Concrete-encased electrode 4. Rod, pipe & plate electrodes 		Copper	Aluminum	Service Rating	NEC 310-15 Conductor Sizes (20/240 VOLT) 3-Wire Single-Phase Dwelling Services/Feeders	<input type="checkbox"/>	4 AWG	2 AWG	100 Amps		<input type="checkbox"/>	1 AWG	2/0 AWG	150 Amps		<input type="checkbox"/>	2/0 AWG	4/0 AWG	200 Amps		<p>M1401.3 Heating and cooling equipment shall be sized based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies.</p> <p style="text-align: center;">Gages of Metal Ducts & Plenums Used for Htg/Cooling</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Type of Ducts</th> <th>Size (inches)</th> <th>Minimum Thickness (Inch)</th> <th>Equip. Galvanized Sheet Gage</th> <th>Approx. Aluminum B & S Gage</th> </tr> </thead> <tbody> <tr> <td rowspan="2">Round Ducts & Enclosed Rectangular</td> <td>14 or less</td> <td>0.013</td> <td>30</td> <td>26</td> </tr> <tr> <td>over 14</td> <td>0.018</td> <td>28</td> <td>24</td> </tr> <tr> <td rowspan="2">Exposed Rectangular Ducts</td> <td>14 or less</td> <td>0.016</td> <td>28</td> <td>24</td> </tr> <tr> <td>over 14</td> <td>0.019</td> <td>26</td> <td>22</td> </tr> </tbody> </table>	Type of Ducts	Size (inches)	Minimum Thickness (Inch)	Equip. Galvanized Sheet Gage	Approx. Aluminum B & S Gage	Round Ducts & Enclosed Rectangular	14 or less	0.013	30	26	over 14	0.018	28	24	Exposed Rectangular Ducts	14 or less	0.016	28	24	over 14	0.019	26	22
	Copper	Aluminum	Service Rating	NEC 310-15 Conductor Sizes (20/240 VOLT) 3-Wire Single-Phase Dwelling Services/Feeders																																								
<input type="checkbox"/>	4 AWG	2 AWG	100 Amps																																									
<input type="checkbox"/>	1 AWG	2/0 AWG	150 Amps																																									
<input type="checkbox"/>	2/0 AWG	4/0 AWG	200 Amps																																									
Type of Ducts	Size (inches)	Minimum Thickness (Inch)	Equip. Galvanized Sheet Gage	Approx. Aluminum B & S Gage																																								
Round Ducts & Enclosed Rectangular	14 or less	0.013	30	26																																								
	over 14	0.018	28	24																																								
Exposed Rectangular Ducts	14 or less	0.016	28	24																																								
	over 14	0.019	26	22																																								
General Circuitry	Access & Installation																																											
<p>NEC 210.11 and 422.12 In addition to the branch circuits installed to supply general illumination and receptacle outlets in dwelling units, the following minimum requirements apply: Two 20-amp circuits for the kitchen receptacles, One 20-amp circuit for the laundry receptacles, One 20-amp circuit for the bathroom receptacles and One separate, individual branch circuit for central heating equipment</p> <p>NEC 210.52 Receptacles installed in the kitchen to serve countertop surfaces shall be supplied by not less than two separate small appliance branch circuits.</p> <p>NEC 210.52 Generally, receptacle outlets in habitable rooms shall be installed so that no point measured horizontally along the floor line in any wall space is more than 6' from a receptacle outlet. A receptacle shall be installed in each wall space 2 feet or more in width.</p> <p>NEC 210.52 At kitchen countertops, receptacle outlets shall be installed so that no point along the wall line is more than 24 inch measured horizontally from a receptacle outlet in that space. Countertop spaces separated by range tops, sinks or refrigerators are separate spaces.</p> <p>NEC 210.52 & 406.8 At least one receptacle, accessible at grade level and no more than 6.5' above grade, shall be installed at the front and back of a dwelling</p> <p>NEC 210.12 All branch circuits supplying 125-volt, 15 and 20 ampere outlets in dwelling unit bedrooms shall be protected by a listed arc-fault circuit interrupter device.</p> <p>NEC 210.8 Ground-fault circuit-interrupter (GFCI) protection shall be provided for all 125-volt, 15 and 20 amp receptacle outlets installed outdoors, in boathouses, garages, unfinished accessory buildings, crawl spaces at or below grade level, unfinished basements, bathrooms, at kitchen countertops and within 6' of the outside edge of the sink in laundry rooms, utility rooms, and at wet-bars.</p>	<p>M1401.2 Heating and cooling equipment shall be located with respect to building construction and other equipment to permit maintenance, servicing and replacement. Clearances shall be maintained to permit cleaning of heating and cooling surfaces; replacement of filters, blowers, motors, controls and vent connections; lubrication of moving parts; and adjustments</p> <p>M1601.3.2 Metal ducts shall be supported by 0.5-inch (12.7 mm) wide 18-gage metal straps or 12-gage galvanized wire at intervals not exceeding 10 feet (3048 mm) or other approved means. Nonmetallic ducts shall be supported in accordance with manufacturer's installation instructions.</p> <p>M1401.4 Equipment installed outdoors shall be listed and labeled for outdoor installation.. Supports and foundations shall prevent excessive vibration, settlement or movement of equipment. Supports and foundations shall be level and conform to manufacturer's installation instructions.</p>																																											
	Plumbing																																											
	<p>All Plumbing Permits and Inspections are handled by the Lake County Health District, Telephone # 440-350-2543.</p>																																											